



2020

# Water Quality Report

This is your annual water quality report for the period of January 1 through December 31, 2020. Each year the Village issues this report to provide you information about the quality of our drinking water, the source of our water, how it is treated, and the regulated compounds it contains. These reports are issued in compliance with the Safe Drinking Water Act. For more detailed information about our water's quality, including test results for unregulated compounds, contact **Jim Bowles at 847-356-6100 x301** or Melissa Olenick at CLCJAWA at 847-295-7788, email at [molenick@clcjawa.com](mailto:molenick@clcjawa.com), or visit the web page at [www.clcjawa.com](http://www.clcjawa.com). *Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.*

Some people may be more vulnerable to drinking water contaminants than the general population. Immune compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. The USEPA and Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA Safe Drinking Water Hotline at 1-800-426-4791.

## EXCELLENCE IN WATER TREATMENT

CLCJAWA has received the Excellence in Water Treatment award for the last 15 years. CLCJAWA was the third facility in the nation to achieve this distinction presented by the Partnership for Safe Water. This voluntary water quality program, sponsored in part by the United States Environmental Protection Agency, holds its awardees to higher standards than required by current Federal and State drinking water regulations.

CLCJAWA was also awarded the Partnership for Safe Water Distribution Director's Award this year, after successfully completing a comprehensive self-assessment of our distribution system. This is a significant achievement towards ensuring the delivery of safe, high-quality water to the community.

**The Village of Lake Villa & CLCJAWA were in full compliance with all state and federal drinking water regulations in 2020.**

## REGULATORY AGENCIES

To ensure tap water safety, the U.S. Environmental Protection Agency (USEPA) prescribes limits on the amount of certain contaminants in our drinking water. Water quality may be judged by comparing our water to USEPA benchmarks for water quality. One such benchmark is the Maximum Contaminant Level Goal (MCLG). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. This goal allows for a margin of safety. Another benchmark is the Maximum Contaminant Level (MCL). An MCL is the highest level of a contaminant that is allowed in drinking water. An MCL is set as close to an MCLG as feasible using the best available treatment technology.

Our tap water quality is consistently monitored by the Village, by the Illinois Environmental Protection Agency (IEPA), in the CLCJAWA Water Quality Lab, and by other independent labs. This aggressive water quality assurance program is thorough: bacteriological tests are conducted six times more often than required, water clarity is monitored every 10 seconds, and our water is checked for over three hundred contaminants annually.

The Village Board has a monthly meeting schedule, and the public is always welcome to attend any of these meetings. Your Mayor is also a member of the Board of Directors of CLCJAWA, which meets regularly. Please visit the website at [www.clcjawa.com](http://www.clcjawa.com) for the current meeting schedule. CLCJAWA provides tours of the water treatment facility, and staff members are also available for public speaking or for school visits. Please contact the Village of Lake Villa or CLCJAWA for more information.

## Water Quality Contaminants Detected in 2020

Contaminant (unit of measure) Typical Source of Contaminant	Highest Level Detected	MCLG	MCL	Range of Detection	Violation	Date of Sample
<b>MICROBIAL CONTAMINANTS</b>						
<b>Total Coliform Bacteria (% Pos/Month)</b> Naturally present; human and animal fecal waste	<b>0</b>	0	5% per month	<b>none</b>	<b>In Compliance</b>	<b>Monthly</b>
<b>E. Coli (% Pos/Month)</b> Naturally present; human and animal fecal waste	<b>0</b>	0	0% per month	<b>none</b>	<b>In Compliance</b>	<b>Monthly</b>
Turbidity (NTU/Lowest Monthly % < 0.3 NTU) Lake Sediment; soil runoff	100% below 0.3 NTU	none	0.3 NTU	100%	In Compliance	Monthly
Turbidity (NTU/Highest Single Measurement) Lake Sediment; soil runoff	0.051	none	1 NTU	0.02 – 0.051	In Compliance	Monthly
<b>INORGANIC CONTAMINANTS</b>						
Nitrate as nitrogen (ppm) Runoff from fertilizer; leaching from septic; natural erosion	0.3	10	10	Single Sample	In Compliance	7/16/2020
Barium (ppm) Discharge of drilling wastes, metal refineries; natural erosion	0.02	2	2	Single Sample	In Compliance	7/16/2020
Chromium (ppb) Discharge from steel, pulp mills; erosion of natural deposits.	1.0	none	100	Single Sample	In Compliance	7/16/2020
<b>Copper (ppm)</b> Corrosion of household plumbing systems; natural erosion	<b>0.34</b> 90 <sup>th</sup> Percentile	1.3	AL = 1.3	<b>0</b> Sites over AL	<b>In Compliance</b>	<b>2020</b>
<b>Lead (ppb)</b> Corrosion of household plumbing systems; natural erosion	<b>1.1</b> 90 <sup>th</sup> Percentile	0	AL = 15	<b>2</b> Sites over AL	<b>In Compliance</b>	<b>2020</b>
<b>DISINFECTANT/DISINFECTION BY-PRODUCTS</b>						
<b>HAA5 Haloacetic Acids (ppb)</b> By-product of drinking water disinfection	<b>9</b>	None	60	<b>5.3 – 15.6</b>	<b>In Compliance</b>	<b>Quarterly</b>
<b>TTHMs Total Trihalomethanes (ppb)</b> By-product of drinking water disinfection	<b>23</b>	None	80	<b>14.42 – 32.8</b>	<b>In Compliance</b>	<b>Quarterly</b>
Bromate (ppb) By-product of drinking water disinfection	1	0	10	0 – 7.8	In Compliance	8/19/2020 Quarterly
<b>Chlorine (ppm)</b> Drinking water disinfectant	<b>1</b>	4	4	<b>1.0 – 1.0</b>	<b>In Compliance</b>	<b>Monthly</b>
TOC (Total Organic Carbon)	The % of TOC removal was measured each month & the system met all removal requirements set by IEPA					
<b>STATE REGULATED CONTAMINANTS</b>						
Fluoride (ppm) Water additive that promotes strong teeth; natural erosion	0.6	4	4	0.6 – 0.6	In Compliance	Monthly
Sodium (ppm) Erosion of naturally occurring deposits; water softener	9.2	none	none	Single Sample	In Compliance	7/16/2020
<b>RADIOACTIVE CONTAMINANTS</b>						
Combined Radium 226/228 (pCi/L) Decay of natural and man-made deposits	0.92	0	5	Single Sample	In Compliance	4/13/15
Gross Alpha Emitters (pCi/L) Erosion of natural deposits	0.39	0	15	Single Sample	In Compliance	4/13/15

The table above lists all of the regulated compounds detected in our water. Bolded compounds were sampled by the Village; all other compounds were sampled by CLCJAWA. The values shown in the level detected column are those used by the EPA to determine compliance with drinking water standards. Because each compound is regulated differently, this value may be a running average, a 90<sup>th</sup> percentile or a maximum single value. The sample data column indicates the date when the sample was collected. When more than one sample is collected, this column shows the date of the maximum value.

### Definition of Terms:

Action Level (AL): level that triggers special treatment or other required action by water plants  
 Maximum Contaminant Level (MCL): the highest level of contaminant that is allowed in drinking water  
 Maximum Contaminant Level Goal (MCLG): level of a contaminant below which there is no known or expected health risk  
 Treatment Technique (TT): required process used to reduce contaminants in drinking water

### Units of Measure:

ppm: parts per million or milligrams per liter  
 ppb: parts per billion or micrograms per liter  
 pCi/: picocuries per liter used to measure radioactivity  
 NTU: nephelometric turbidity unit that measures clarity in drinking water

## OUR SOURCE WATER

The Illinois EPA, using the Great Lakes Protocol, completed source water assessment in April 2003. Lake Michigan is a surface water source and like all surface waters, is susceptible to potential contaminants. The very nature of surface water allows contaminants to migrate to the intake with no protection, only dilution. CLCJAWA's intake is ranked as moderately sensitive to potential contaminants. There are no potential contamination sources within the intake's critical assessment zone. However, the combination of land use, storm sewer outfalls, and the proximity of North Shore Water Reclamation District (NSWRD) pumping stations in the immediate area add to the susceptibility of CLCJAWA's intake. NSWRD discharges their treated waste water to the Des Plaines River and not into Lake Michigan. Access the following website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl> to view a summary of the source water assessment. We are all participants in the water cycle. Our individual activities impact the rivers and lakes in our watershed and those into which our waste water plants discharge. Please properly use, store, and dispose of all medications and household chemicals. Visit the Solid Waste Agency of Lake County website for disposal options and information at [www.swalco.org](http://www.swalco.org).

Villages purchase water from the Central Lake County Joint Action Water Agency. CLCJAWA is an inter-governmental cooperative, directed by the communities it serves: Grayslake, Gurnee, Lake Bluff, Lake Villa, Libertyville, Lindenhurst, Mundelein, Round Lake, Round Lake Beach, Round Lake Heights, Round Lake Park, Volo, Wauconda and Lake County representing the unincorporated areas of Knollwood and Rondout, Vernon Hills, Wildwood, Grandwood Park and Fox Lake Hills.

CLCJAWA utilizes over 50 miles of pre-stressed concrete, ductile iron and PVC water main to deliver water to your community. The Village of Lake Villa in turn, maintains its own water distribution system that delivers the water to homes, schools and businesses in the community.

The Village of Lake Villa maintains two elevated water towers and two ground storage tanks with a combined capacity of 3.1 million gallons of water storage. A main pumping station feeding over 45 miles of water mains ranging from 6 inch to 12 inches diameter providing an average 550,000 gallons per day or just over 211 million gallons last year to customers. Daily sampling and water quality monitoring provides safe drinking water year round.

The Village of Lake Villa maintains 9 emergency back-up wells. They are ran and sampled monthly for coliform and other contaminants with the water being pumped to waste. The back-up well testing results are not included in this report, but can be provided upon request to the village.

## THE TREATMENT PROCESS

Our water is pumped from Lake Michigan and treated at CLCJAWA's Paul M. Neal Water Treatment Facility in the Village of Lake Bluff. The enhanced water purification process used by CLCJAWA is unique. First, the water is treated with ozone to kill organisms and break down contaminants. Ozone is produced on-site from air, bubbled into the water, and then converted back into oxygen. The water is then mixed with coagulant to remove sediment and other material from the water. Once clarified, the water is further refined as it passes through filters containing activated carbon and fine sand to remove any remaining cloudiness or turbidity. Turbidity is then measured to determine water clarity. Treatment facilities monitor turbidity because it is a good indicator of water quality and the effectiveness of their filtration and disinfection systems. At CLCJAWA, turbidity is checked every ten seconds in numerous locations by automatic monitoring equipment and twice a day, by hand, in the laboratory (see results on page 2). Next the water is treated with ultraviolet light to inactivate any remaining organisms. Finally, the purified water is treated with chlorine to protect it as it travels through the water main, fluoride for dental health, and a small amount of an often-used food additive called phosphate. Phosphate protects the water from metals, such as lead and copper, found in our homes' plumbing systems.

## LAKE MICHIGAN EXPOSURE TO CONTAMINANTS

Drinking water, including bottled water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the US Environmental Protection Agency's (USEPA) Safe Drinking Water Hotline at 1-800-426-4791. Both tap and bottled water come from rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring materials and can pick up substances resulting from the presence of animal or human activity. Contaminants that may be present in untreated water include:

- Microbial contaminants such as viruses and bacteria can be naturally occurring or may come from sewage treatment plants, septic systems, and livestock operations.
- Inorganic contaminants such as salts and metals can be naturally occurring or result from urban storm water runoff, wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides come from sources such as agricultural, urban and residential storm water runoff.
- Organic chemical contaminants including synthetic and volatile organic compounds are by-products of industrial processes and petroleum production but can also come from gas stations, urban storm water runoff and septic system.
- Radioactive contaminants can be naturally occurring or be the result of oil, gas and mining activities. Pesticides and herbicides come from sources such as agricultural and residential storm water runoff.

## LEAD AND DRINKING WATER

Elevated levels of lead can cause serious health problems, especially in pregnant women and young children. Some homes with old lead service lines, lead plumbing, or copper plumbing with lead solder, may have lead and copper in their water. To minimize these levels, the Illinois EPA requires that CLCJAWA add phosphate to our water at a concentration of 0.3 ppm orthophosphate. This commonly used food ingredient thinly coats the inside of your premise plumbing.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. For the best quality and to minimize the potential for lead and copper exposure, you may flush your tap until the water is cool or for 30 seconds to 2 minutes before using the water for drinking or cooking. To know with certainty whether you have lead or copper in your drinking water, have your water tested at a certified laboratory.

Water providers are now generating an inventory of all known lead service lines in use, and are issuing public notification to homeowners of local water main construction or repair work that might increase the risk of lead exposure. For more information on lead in drinking water, testing methods and steps you can take to minimize exposure, contact the Safe Drinking Water Hotline at 1-800-426-4791 or go to <http://www.epa.gov/safewater/lead>.



65 Cedar Avenue - Lake Villa, IL  
847-356-6100 - [www.lake-villa.org](http://www.lake-villa.org)

Central Lake County  
Joint Action Water Agency  
200 Rockland Road  
Lake Bluff, IL 60044  
847-295-7788  
[www.CLCJAWA.com](http://www.CLCJAWA.com)

